


Introduction about connector changed of SunESS HV stacked product

1. Related product model:


SunESS-H/SunESS Power All in One

2. Contents Changed:


① Connector



② Pre-change vs. Post-change (Example: battery pack)



Pre-change (Connector A)



Post-change (Connector B)


3. Impact of change






The products with different connectors (A and B) **cannot be stacked and mixed with each other**. Mixed use cause connector damage. Please follow the instructions below to distinguish and correct installation.

4. Instructions for distinguish:


① Distinguish the color of packaging carton (Battery module/ Control module /Inverter module) **Pre-change vs. Post-change**

Pre-change packaging carton	Post-change packaging carton
Battery module 	
Control module+Base 	
Inverter module+Base 	


② Distinguish the labels on battery shell. (Remove the packaging carton)

Pre-change Battery module shell	Post-change Battery module shell
	  blister cover  warning label Blister cover: Remove blister cover and separate from warning label prior to installation. Warning label: Content: Due to connector differences, only stack batteries with labels. Do not mix with unlabeled batteries.

③ Distinguish the labels on Control module shell. (Remove the packaging carton)

Pre-change Control module shell	Post-change Control module shell
	 Warning label①: This label is detachable when installed. Content: Due to connector differences, only stack batteries with labels. Do not mix with unlabeled batteries. Warning label②: This label is fixed paste. Content: Due to connector differences, only stack batteries with labels. Do not mix with unlabeled batteries.

④ Distinguish the labels on Inverter module shell. (Remove the packaging carton)



Pre-change Inverter module shell	Post-change Inverter module shell
	 Warning label①: This label is detachable when installed. Content: Due to connector differences, only stack batteries with labels. Do not mix with unlabeled batteries. Warning label②: This label is fixed paste. Content: Due to connector differences, only stack batteries with labels. Do not mix with unlabeled batteries.



Please stack and install the labeled products,
Do not stack labeled and unlabeled products together.
Unlabeled products can only stack with unlabeled ones.
Please contact our professional technician to confirm the connector version before replacing the battery pack, do not operate privately.

Appendix:

As the new connectors are switched over, the base plan will also be new, with the following differences:

Pre-change Base	Post-change Base
 Height: 80mm  Weight: 5.2Kg	 Height: 37.5mm  Optional: Leveling foot Weight: 3.2Kg (Leveling foot not included) Leveling foot: Weight: 0.46Kg (4 Leveling feet) Height: 32mm-42mm